

Energy Performance Certificate

Non-Domestic Building



Units D, E and F
Hambridge Road
Hambridge Road Industrial Estate
NEWBURY
RG14 5SS

Certificate Reference Number:
0922-3057-0419-0900-6591

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Asset Rating

More energy efficient

A+

..... Net zero CO₂ emissions

A 0-25

B 26-50

C 51-75

D 76-100

E 101-125

F 126-150

G Over 150

◀ **125** This is how energy efficient the building is.

Less energy efficient

Technical information

Main heating fuel:	Natural Gas
Building environment:	Heating and Natural Ventilation
Total useful floor area (m ²):	982
Building complexity (NOS level):	3

Benchmarks

Buildings similar to this one could have ratings as follows:

36 If newly built

72 If typical of the existing stock

Administrative information

This is an Energy Performance Certificate as defined in SI2007:991 as amended

Assessment Software:	ISBEM v3.3.b using calculation engine SBEM v3.3.b
Property Reference:	929459520000
Assessor Name:	Andrew Allmark
Assessor Number:	BREC400078
Accreditation Scheme:	BRE Global
Employer/Trading Name:	Whitecroft Green Limited
Employer/Trading Address:	81, Markand Hill, Heaton, Bolton, BL1 5NU
Issue Date:	20 Apr 2009
Valid Until:	19 Apr 2019 (unless superseded by a later certificate)
Related Party Disclosure:	We are not aware of any conflicts of interest at the time of undertaking this assessment.
Recommendations for improving the property are contained in Report Reference Number:	0690-0941-2490-2597-5002


If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from the Government's website at www.communities.gov.uk/epbd, together with details of the procedures for confirming authenticity of a certificate and for making a complaint.



For advice on how to take action and to find out about technical and financial assistance schemes to help make buildings more energy efficient visit www.carbontrust.co.uk or call us on 0800 085 2005

Recommendation Report



Report Reference Number: 0690-0941-2490-2597-5002

Units D, E and F
 Hambridge Road
 Hambridge Road Industrial Estate
 NEWBURY
 RG14 5SS

Building Type(s): Office

ADMINISTRATIVE INFORMATION	
Issue Date:	20 Apr 2009
Valid Until:	19 Apr 2019 (*)
Total Useful Floor Area (m ²):	982
Calculation Tool Used:	iSBEM v3.3.b using calculation engine SBEM v3.3.b
Property Reference:	929459520000

ENERGY ASSESSOR DETAILS	
Assessor Name:	Andrew Allmark
Employer/Trading Name:	Whitecroft Green Limited
Employer/Trading Address:	81, Markland Hill, Heaton, Bolton, BL1 5NU
Assessor Number:	BREC400078
Accreditation scheme:	BRE Global
Related Party Disclosure:	We are not aware of any conflicts of interest at the time of undertaking this assessment.

Table of Contents

1. Background..... 3

2. Introduction..... 3

3. Recommendations..... 4

4. Next Steps..... 6

5. Glossary..... 8

1. Background

Statutory Instrument 2007 No. 991, *The Energy Performance of Buildings (Certificates and Inspections) (England and Wales) Regulations 2007*, as amended, transposes the requirements of Articles 7.2 and 7.3 of the Energy Performance of Buildings Directive 2002/91/EC.

This report is a Recommendation Report as required under regulations 16(2)(a) and 19 of the Statutory Instrument SI 2007:991.

This section provides general information regarding the building:

Total Useful Floor Area (m ²):	982
Building Environment:	Heating and Natural Ventilation

2. Introduction

This Recommendation Report was produced in line with the Government's approved methodology and is based on calculation tool ISBEM v3.3.b using calculation engine SBEM v3.3.b.

In accordance with Government's current guidance, the Energy Assessor did undertake a walk around survey of the building prior to producing this Recommendation Report.

3. Recommendations

The following sections list recommendations selected by the energy assessor for the improvement of the energy performance of the building. The recommendations are listed under four headings: short payback, medium payback, long payback, and other measures.

a) Recommendations with a short payback

This section lists recommendations with a payback of less than 3 years:

Recommendation	Potential Impact
Replace 38mm diameter (T12) fluorescent tubes on failure with 26mm (T8) tubes.	LOW
Consider replacing T8 lamps with retrofit T5 conversion kit	LOW
Some spaces have a significant risk of overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	MEDIUM
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	LOW

b) Recommendations with a medium payback

This section lists recommendations with a payback of between 3 and 7 years:

Recommendation	Potential Impact
Some walls have uninsulated cavities - introduce cavity wall insulation.	MEDIUM
Some windows have high U-values - consider installing secondary glazing.	MEDIUM

c) Recommendations with a long payback

This section lists recommendations with a payback of more than 7 years:

Recommendation	Potential Impact
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	MEDIUM
Consider installing solar water heating.	LOW

Roof is poorly insulated. Install or improve insulation of roof.	MEDIUM
Consider installing PV.	LOW

d) Other recommendations

This section lists other recommendations selected by the energy assessor, based on an understanding of the building, and / or based on a valid existing energy report.

No recommendations defined by the energy assessor have been identified

4. Next steps

a) Your Recommendation Report

As the building occupier, regulation 10(1) of SI 2007:991 requires that an Energy Performance Certificate "*must be accompanied by a recommendation report*".

You must be able to produce a copy of this Recommendation Report within seven days if requested by an Enforcement Authority under regulation 39 of SI 2007:991.

This Recommendation Report has also been lodged on the Government's central register. Access to the report, to the data used to compile the report, and to previous similar documents relating to the same building can be obtained by request through the Non-Dwellings Register (www.epcregister.com) using the report reference number of this document.

b) Implementing recommendations

The recommendations are provided as an indication of opportunities that appear to exist to improve the building's energy efficiency.

The calculation tool has automatically produced a set of recommendations, which the Energy Assessor has reviewed in the light of his / her knowledge of the building and its use. The Energy Assessor may have comments on the recommendations based on his / her knowledge of the building and its use. The Energy Assessor may have inserted additional measures in section 3d (Other Recommendations). He / she may have removed some automatically generated recommendations or added additional recommendations.

These recommendations do not include matters relating to operation and maintenance which cannot be identified from the calculation procedure.

c) Legal disclaimer

The advice provided in this Recommendation Report is intended to be for information only. Recipients of this Recommendation Report are advised to seek further detailed professional advice before reaching any decision on how to improve the energy performance of the building.

d) Complaints

Details of the assessor and the relevant accreditation scheme are on this report and the energy performance certificate. You can get contact details of the accreditation scheme from our website at www.communities.gov.uk/epbd, together with details of their procedures for confirming authenticity of a certificate and for making a complaint.

5. Glossary

a) Payback

The payback periods are based on data provided by Good Practice Guides and Carbon Trust energy survey reports and are average figures calculated using a simple payback method. It is assumed that the source data is correct and accurate using up to date information.

The figures have been calculated as an average across a range of buildings and may differ from the actual payback period for the building being assessed. Therefore, it is recommended that each suggested measure be further investigated before reaching any decision on how to improve the energy efficiency of the building.

b) Carbon Impact

The High / Medium / Low carbon impact indicators against each recommendation are provided to distinguish, between the suggested recommendations, those that would have most impact on carbon emissions from the building. For automatically generated recommendations, the carbon impact indicators are determined by software, but may have been adjusted by the Energy Assessor based on his / her knowledge of the building. The impact of other recommendations are determined by the assessor.

c) Valid report

A valid report is a report that has been:

- Produced within the past 10 years
- Produced by an Energy Assessor who is accredited to produce Recommendation Reports through a Government Approved Accreditation Scheme
- Lodged on the Register operated by or on behalf of the Secretary of State.

SBEM Main Calculation Output Document

Mon Apr 20 00:05:10 2009


Building name

Units DEF Hambridge

Building type: Office

SBEM is an energy calculation tool for the purpose of assessing and demonstrating compliance with Building Regulations (Part L for England and Wales, Section 6 for Scotland, Part F for Northern Ireland and Part L for Republic of Ireland) and to produce Energy Performance Certificates and Building Energy Ratings. Although the data produced by the tool may be of use in the design process, **SBEM is not intended as a building design tool.**


Building Energy Performance and CO2 emissions




0 kgCO2/m2 displaced by the use of renewable sources.

Building area is 981.6m2

Annual Energy Consumption



(Pie chart excluding Equipment end-use)



(*) Although energy consumption by equipment is shown in the graphs, the CO2 emissions associated with this end-use have not been taken into account when producing the rating.

